



Date:-03.06.2023

To,

The Principal,  
K.L.E.Society's M.R.Sakhare English Medium School  
Vidyanagar,  
HUBBALLI -31

Madam,

Sub: - Testing of Drinking Water

With reference to the above following are the test results of water Sample sent by you to our Laboratory

Sl No	Parameter	Results	Permissible Limits as per IS 10500-2012
1	p <sup>h</sup>	7.5	6.4 to 8.4
2	Alkalinity mg/1	66	240
3	Chloride mg/1	37	255
4	Hardness MG/1	78	290
5	Dissolved oxygen mg/1	3.7	4.00 Minimum
6	Total Solids mg/1	168	490

The Sample given for test is fit for drinking purpose

Site in charge

Co-Ordinator

**PRINCIPAL**  
**M.R.SAKHARE Eng. Med. School CBSE**  
**Vidyanagar, HUBBALLI-31**